Cathy Flynn

From: Tate Keogan <acktate@yahoo.com>
Sent: Tuesday, July 07, 2020 11:55 AM
To: Cathy Flynn
Cc: Cathy Flynn
Subject: Re: HDC application question

Hi Cathy.

Hope your well. We just want to be thorough and flow all the rules.

We want to remote set the condensing units due to the propane line entering the building where they were originally supposed to go. You cannot have a ignition source closer than 10ft to the gas regulator. Reason to move away from building. The fence was originally a condition in our original approval so we are just asking to relocate the AC condensing units

Proposed fence is 5’,10” and 16’ long.

Front door we had to change the 2 light to a 4 because the bullseye glass manufacturer could not make the glass panes that large. The 4 light I feel is more appealing and historic. Nantucket Millworks made the custom mahogany door.

Pictures attached from Daffodil lane.

I also have attached a picture of our landscape design which will further shields the porch and door from Daffodil Lane for additional privacy.

Thanks any questions or concerns or additional pictures let me know.

Also my cell is 508-325-1691.

5
Keogan

ACER RUBRUM
MULTI
ANNUAL/
PERENNIAL
BUXUS 'GREEN
MOUNTAIN'
WW
PORCH
BLUESTONE
WALKWAY
(R) 26'
16'
ANNUAL/PERENNIAL
PLANTINGS
BUXUS 'GREEN VELVET'
LAWN
ACER RUBRUM
(MULTI STEM)
ARGUTE BADDAL VERD
ZELKOVA
NEREIA
LAWN
PENNISETUM 'HAMLIN'
BETULA NIGRA
HAMAMELIDA