

**ENVIROTECH LABORATORIES, INC.**  
**MA CERT. NO.: M-MA 063**

8 Jan Sebastian Drive  
 Sandwich, MA 02563  
 (508)888-6460 1-800-339-6460  
 FAX (508)888-6446

Thursday, January 11, 2018


Sarian Company  
 8 Jan Sebastian Dr, Unit 24  
 Sandwich MA 02563

**ProjectName:** Sewer Investigation **Comments:**  
**Project Number:** NA  
**Sampled By:** Client  
**Lab Order Number:** WW-180036  
**Date Received:** 01/09/18

Sample Type	Sample Time	Sample Date	Comments			
Easy St. Bulkhead A	9:35	1/9/18	Easy St. Bulkhead			
Parameters	Units	Test Results	Reportable Limits	Date Analyzed	Analyst	Method
Kjeldhal Nitrogen	mg/L	1.3	0.60	01/11/18	KB	SM4500-Norg B-C
Nitrate-N	mg/L	0.59	0.01	01/09/18	RL	EPA 300.0
Nitrite-N	mg/L	BRL	0.006	01/09/18	RL	EPA 300.0
Total Nitrogen	mg/L	1.9	NA	01/11/18	KB	Calculation
Total Phosphorous (P)	mg/L	0.343	0.005	01/10/18	MC	SM 4500-P-B,E
Ortho Phosphorous (P)	mg/L	0.237	0.005	01/10/18	MC	SM 4500-P
Sample Type	Sample Time	Sample Date	Comments			
Y.C. Discharge B	9:55	1/9/18	Yacht Club Discharge			
Parameters	Units	Test Results	Reportable Limits	Date Analyzed	Analyst	Method
Kjeldhal Nitrogen	mg/L	0.93	0.60	01/11/18	KB	SM4500-Norg B-C
Nitrate-N	mg/L	0.27	0.01	01/09/18	RL	EPA 300.0
Nitrite-N	mg/L	BRL	0.006	01/09/18	RL	EPA 300.0
Total Nitrogen	mg/L	1.2	NA	01/11/18	KB	Calculation
Total Phosphorous (P)	mg/L	0.263	0.005	01/10/18	MC	SM 4500-P-B,E
Ortho Phosphorous (P)	mg/L	0.149	0.005	01/10/18	MC	SM 4500-P
Sample Type	Sample Time	Sample Date	Comments			
Y.C Opp Side C	10:00	1/9/18	Yacht Club Opposite Side			
Parameters	Units	Test Results	Reportable Limits	Date Analyzed	Analyst	Method
Kjeldhal Nitrogen	mg/L	17	0.60	01/11/18	KB	SM4500-Norg B-C
Nitrate-N	mg/L	BRL	0.01	01/09/18	RL	EPA 300.0
Nitrite-N	mg/L	BRL	0.006	01/09/18	RL	EPA 300.0
Total Nitrogen	mg/L	17	NA	01/11/18	KB	Calculation
Total Phosphorous (P)	mg/L	0.987	0.005	01/10/18	MC	SM 4500-P-B,E
Ortho Phosphorous (P)	mg/L	0.323	0.005	01/10/18	MC	SM 4500-P

BRL=below reportable limits

\*see attached

By:   
 Ronald J. Saari  
 Laboratory Director

**ENVIROTECH LABORATORIES, INC.**  
**MA CERT. NO.: M-MA 063**

8 Jan Sebastian Drive  
 Sandwich, MA 02563  
 (508)888-6460 1-800-339-6460  
 FAX (508)888-6446

Thursday, January 11, 2018

Sarian Company  
 8 Jan Sebastian Dr, Unit 24  
 Sandwich MA 02563

**ProjectName:** Sewer Investigation  
**Project Number:** NA  
**Sampled By:** Client  
**Lab Order Number:** WW-180036  
**Date Received:** 01/09/18

**Comments:**

Sample Type	Sample Time	Sample Date	Comments			
South Beach St. D	11:30	1/9/18	South Beach Street			
Parameters	Units	Test Results	Reportable Limits	Date Analyzed	Analyst	Method
Kjeldhal Nitrogen	mg/L	27	0.60	01/11/18	KB	SM4500-Norg B-C
Nitrate-N	mg/L	0.65	0.01	01/09/18	RL	EPA 300.0
Nitrite-N	mg/L	BRL	0.006	01/09/18	RL	EPA 300.0
Total Nitrogen	mg/L	28	NA	01/11/18	KB	Calculation
Total Phosphorous (P)	mg/L	3.70	0.005	01/10/18	MC	SM 4500-P-B,E
Ortho Phosphorous (P)	mg/L	3.44	0.005	01/10/18	MC	SM 4500-P

BRL=below reportable limits

\*see attached

By:   
 Ronald J. Saari  
 Laboratory Director